

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Exceeded Maximum Contaminant Level (MCL) for Total Trihalomethanes

MINERAL WELLS PSD, WV3305405

Our water system recently violated a drinking water standard. Although this is not an emergency, you, as our customers have the right to know what happened, what you should do, and what we are doing to correct the situation.

We routinely monitor for the presence of drinking water contaminants. Test results for 10/1/2024 and 12/31/2024 show that our system exceeds the standard or maximum contaminant level (MCL) for Total Trihalomethanes.

The average level of Total Trihalomethanes over the last four quarters was 82.000000000µg/L at WINDY & SCIENCE HILL ROADS location. The standard for Total Trihalomethanes is 80.0µg/L.

What should I do?

You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, it is recommended that you consult with your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing *Total Trihalomethanes (TTHM's)* in excess of the MCL over many years may have an increased risk of getting cancer.

What happened? What is being done? (Describe corrective action)

The average level of Total Trihalomethanes over the last four quarters was 82.000000000 ug/L at Windy & Science Hill Roads location. The standard for Total Trihalomethanes is 80.0 ug/L. The system will be flushed to correct the issue.

For more information, please contact Todd Anderson at 304-489-2915
(Contact name) (Phone number)

Or PO Box 266 Mineral Wells, WV 26150
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: MINERAL WELLS PSD 12/5/2024

State Water System ID #: WV3305405 Date Distributed: 1/10/25